City Engineer Approved: BLO 08/23/2019 Public Works Approved: RAS 08/23/2019 City Council Approved: 07/17/2019

Exterior Work Installation Checklist:

Lot Grading

All referenced Specifications and Details are found in the latest edition of the City of Kindred Standard Specifications for Construction.

		Detailed Grading Plan for Home Site Graded in accordance with Lot Grading Exhibit Top of Foundation Elevation: 24" to 36" above street gutter elevation Sidewalk Elevation: 12" above street gutter elevation Rear Yard: in accordance with overall plat grading plan
Sidewalks & Driveways		
		Install sidewalks in accordance with Standard Detail 750-2. Install driveway in accordance with Standard Detail 750-1. ☐ Install driveway crossing plate for existing or future sidewalk per detail 750-2.
		Grade sidewalks in accordance with Lot Grading Exhibit
Water Service		
		All water services outside of the building to be in accordance with Section 331417 – Site Water Utility Laterals.
		Minimum water service size of 1".
		Provide a minimum of 7'-6" of cover over service line from finished grade.
		Adjust Utility access casting, curb stop, and trace wire access box to finished grade.
		Extend trace wire to house and install access box at termination.
Sewer Service		
		All sewer services outside of the building to be in accordance with Section 333111- Public Sanitary Sewerage Gravity Piping
		Provide minimum slope
		☐ 1/4" per foot for 4" sewer service pipe
		☐ 1/8" per foot for 6" sewer service pipe
		Provide a minimum of 7'-6" of cover over service line from finished grade or provide insulation for shallower installations.
		Adjust trace wire access box to finished grade.
		Extend trace wire to house and install access box at termination.
Erosion Control		
		Provide concrete washout on property.
		Provide silt fence around perimeter to protect neighboring properties.
		Provide rock driveway to limit tracking onto public streets.